

Recessed


Create 70-78 mm hole where the lamps shall install
The use a 70-78 mm hole saw and a half round raps for making a suitable hole . Plug the cable to the terminal block

GENERAL INSTRUCTIONS

THESE INSTRUCTIONS SHOULD BE READ CAREFULLY AND RETAINED AFTER INSTALLATION FOR FURTHER REFERENCE AND MAINTENANCE

SAFETY INSTRUCTIONS

- Before installation or maintenance ensure that the mains supply to the luminaire is switched off and the circuit supply fuses are removed or circuit breaker turned off
- A qualified electrician **MUST** be consulted or used for the installation of this luminaire
- Check that the total load in to the circuit,including when this luminaire is fitted ,does no exceed the rating of the circuit cable fuse or circuit breaker



INSTALLATION INSTRUCTIONS

CODE	IP Rating	Cut out
ELV-55	IP65	ø 70-78

