



CHNT

NB310L

B16 $I_{\Delta n} 0.03A$

6000 $t \leq 0.1s$



3

400V~

IEC/EN61009-1



660036



Test regularly

KEMA KEUR

CE

IPT EMAT groepenkasten BV
Welthouder Beverstrat
189/7543BK Enschede The
Netherlands

