

# Alecto

SA-18

PD-0620

Rookmelder / Détecteur de Fumée  
Photoelectric Smoke Alarm / Optischer Detektor

Voeding  
Alimentation  
Batterienversorgung



Alecto service:  
Australielaan 1  
5232 BB 's-Hertogenbosch  
(+31)(0)73 6411 355



v1.2

CE  
13  
1134-CPL-124  
KD-1270  
801CPL2018-07-13

Made in China

NL: Test wekelijks en na plaatsing batterij, totaal vervangen in 04/2028  
GB: Test weekly and after battery placement, replace completely in 04/2028  
FR: Testez toutes les semaines, remplacez complètement en 04/2028  
D: Führen Sie wöchentlich und nach dem Wechsel der Batterie einen Test durch. Einen kompletten Austausch des Gerätes ist in 04/2028 erforderlich.  
WARNING! Refer to instruction manual before use! Sound emission in alert mode min. 85dB. Use following recommended battery only. Pairdeel 6F22  
Kuling 192 G.CCA. Complies with standard EN14604:2005/AC:2008.

