



CHNT

NB310L

B20 $I_{\Delta n}$ 0.03A


6000 $t \leq 0.1s$

3

400V~

IEC/EN61009-1


660037



Test regularly

KEMA
KEUR

CE



IPT EMAT groepenkasten BV
Wethouder Beverstrat
18977543BK Enschede /The
Netherlands

