

Alecto

SA-18

PD-0620

Rookmelder / Détecteur de Fumée
Photoelectric Smoke Alarm / Optischer Detektor

Voeding
Alimentation
Batterieverzorging



Alecto service:

Australielaan 1
5232 BB 's-Hertogenbosch
(+31)(0)73 6411 355



v1.2

CE
13
1134-CPL-124
KD-1270
801CPL2018-07-13

Made in China

NL: Test wekelijks en na plaatsing batterij, totaal vervangen in 04/2028
GB: Test weekly and after battery placement, replace completely in 04/2028
FR: Testez toutes les semaines, remplacez complètement en 04/2028
D: Führen Sie wöchentlich und nach dem Wechsel der Batterie einen Test durch. Einen kompletten Austausch des Gerätes ist in 04/2028 erforderlich.
WARNING! Refer to instruction manual before use! Sound emission in alert mode min. 85dB. Use following recommended battery only. Pairdeel 6F22
Klang 9V, G.CCA, Complies with standard EN14604:2005/AC:2008.

