

Alecto®


SA-18

PD:0421

Rookmelder / Détecteur de Fumée

Photoelectric Smoke Alarm / Optischer Detektor

Voeding
Alimentation:
Stromversorgung:



Alecto service:

Australiëlaan 1

5232 BB 's-Hertogenbosch

(+31)(0)73 6411 355



V1.2



1134-CPR-1

KD-127G

001CPR2016-0

made in C

: Test wekelijks en na plaatsing batterij, totaal vervangen in 04/2031
B: Test weekly and after battery placement, replace completely in 04/2031
R: Testez toutes les semaines, remplacer complètement en 04/2031
Führen Sie wöchentlich und nach dem Wechsel der Batterie einen Test durch. Einen kompletten Austausch des Gerätes ist in 04/2031 erforderlich.

WARNING! Refer to instruction manual before use! Sound emission in alert mode min.85dB. Use following recommended battery only: Pairdeer 6F22
Rating: 9V, 0.02A. Complies with standard EN14604:2005/AC:2008.

MERCURY FREE

AIRDEER