

# ogniochron

## FIRE EXTINGUISHER



1 PULL OUT PIN.

2 AIM HOSE AT BASE OF FIRE AND PRESS LEVER. USE IN UPRIGHT POSITION.



**CAN BE USED FOR EXTINGUISHING OF ELECTRIC DEVICES UP TO 1000 V - KEEP THE DISTANCE MIN. 1m**



INSPECTION SHOULD BE MADE EVERY 12 MONTHS AT LEAST. USE ONLY SPARE PARTS IN ACCORDANCE WITH APPROVED SAMPLE OF FIRE EXTINGUISHER.

**REFILL FIRE EXTINGUISHER AFTER EACH USAGE!**



EXTINGUISHING AGENT: 2 kg FUREX PRO  
PROPELLANT: NITROGEN 12 bar AT TEMP. +20°C  
SCOPE OF APPLICATION TEMPERATURES: -30°C TO +60°C




CERTIFICAT NO. SP 241/18 ACC. EN 3-7  
TYPE GP-2x ABC

Manufacturer:

**KZWM OGNIОCHRON S.A.**

ul. Krakowska 83c, 34-120 Andrychów, POLAND  
tel. +48 33 875 10 70, fax +48 33 875 10 77  
e-mail: export@ogniochron.eu, www.ogniochron.eu



Production date:

2018 | 2019 | 2020 | 2021 | 2022