

Single Station Smoke Alarm


10 year sealed battery

Normal operation: Red LED flashing once every 50 seconds.

Alarm status: Red LED flashes rapidly, and the buzzer sounds a "beep, beep, beep". **Hush:** Red LED flashes 9 seconds and the buzzer does not sound. (Silence time is about 9min) **Fault:** Red LED flashes once every 8 seconds with one "beep"; Replace alarm. **Low battery :** Red LED flashing once every 50 seconds with one "beep"; Replace alarm.

Not recommended for operation below 0°C or above 40°C or in humidity higher than 93% RH. Test the alarm weekly.

Factory State:
press the accessory and
then fasten the base

 **WARNING — Battery not replaceable — See instruction manual**

Distributed by:

Dependo
Boterbloem 9 ■ Info@dependo.nl
2671WS Naaldwijk ■ www.dependo.nl

ON

OFF Factory State Date of manufact

Installation date: _____ Repl: **2022-07-14**
010112022030300047

CE

1008
1008-CPR-69265137
DOP:



EN14604:2005

Made in china