



Chaussée de Ybroude, 139  
Waremme/serresweg 139  
B-1200 Bruxelles/Brussel  
TEL: 32 (0)2 264 03 50  
FAX: 32 (0)2 266 89 53  
<http://www.apragaz.com>  
[info@apragaz.com](mailto:info@apragaz.com)

**NOTIFIED BODY EU TYPE EXAMINATION CERTIFICATE**

In accordance with module B "Production Type" of the  
Pressure Equipment Directive 2014/68/EU

Certificate N°  
14/IT/3543-0-REV 2

<b>Manufacturer</b>	Name	<b>ANAF FIRE PROTECTION S.P.A.</b>
	Address	<b>Via del Commercio 4 I-27020 Torre d'Isola (Pavia) ITALY</b>

**Concerned Equipment:** Portable Fire Extinguishers (Powder Stored Pressure)

**Type:** PS3-HX ABC - according to technical design ref. - 33.692 C-F000.00 Rev. A

**Capacities:** 3 kg

**Set pressure:** max. 18,5 bar (+60°C)

**Test pressure:** PT = 27 bar / Bursting pressure: Pr ≥ 55 bar

**Service temperature range:** min. -30°C / max. +60°C

The manufacturer is allowed to affix the CE Mark to the approved equipment in the conditions described in article 19 of the Directive, only if the requirements stated in module D are fully complied with.

**The approval is valid until 01/09/2024.**

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/EU, certifies that the design of these pressure vessels conforms to the relevant requirements of the pertinent EN3 standards in force and the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.

Date :07/08/2017

Name : Ch. Leplat

Position **General Manager**

Notified body  
identification number :

0029

Signature

*Ch. Leplat*

Notified body name :

**APRAGAZ**  
Belgium  
Inspecting  
Authority

Notified body reference :

P4434/050

