



Model: DVM-SA30 (Photoelectric Smoke Alarm)
Batch NO.: 202206 **Replace By End:** 2032.06
Battery Spec.: DC 3V(CR123A)

WARNING:

• Test weekly. • Battery not replaceable. • Read the user's manual before installing and operating. • Clean by vacuum, cleaning the outside of the unit each month, refer to user's manual. • The red LED will flash every 8 seconds, indicates the smoke alarm is running into the silence(Hush) mode. • An intermittent "chirp" with red LED flashes once every 48 seconds, indicates a low battery, Please replace the smoke alarm.

DVM International B.V.
Vierlaan 53735 KT Bosch en Duin Netherlands
Tel: +31 85 0602388 E-mail: info@dvm-i.com
Made in China



8 172 029 9 17 8 8 7 3 2 1



1116-CPR-132
DoP: RD-380A-H-24-001
EN 14604:2005/AC:2008 Ver: 1.0

78.00 mm

41.30 mm