



## **Declaration of Conformity**

For the following equipment:

Product Name: Switching Power Supplies

Model Designation: HLG-240x-yz (x=H or blank; y=12,15,20,24,30,36,42,48 or 54; z=A ,B ,C or blank)

HLG-240H-24SI

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

## RoHS Directive (2011/65/EU) Low Voltage Directive (2014/35/EU):

EN60950-1:2006+A11+A1+A12+A2 CB certificate No: DK-50588-A1-UL

## **Electromagnetic Compatibility Directive (2014/30/EU):**

**EMI (Electro-Magnetic Interference)** 

Conducted emission / Radiated emission

EN55022:2010

EN55032:2015+AC:2016

Class B

Harmonic current EN61000-3-2:2014

Voltage flicker EN61000-3-3:2013

## **EMS (Electro-Magnetic Susceptibility)**

The (Tieste magnetic casespainity)			
EN55024:2010+A1:2015	EN61000-6-2:2005+AC:2005		
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-11:2004 >95% dip 0.5 periods	30% dip 25 per	iods >95% interruptions 250 periods

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies" (as available on http://www.meanwell.com)" and TDF (Technical Documentation File).

This Declaration is effective from serial number RB7xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification Center:

(Name / Position)

Ted Cheng/Director, Sales Dept. : (Signature) (Name / Position)

Taiwan Jan. 23th, 2017

(Place) (Date)