

$I_e$ (A)	$U_e$ (V-50/60Hz)	400	440	500	690
0.63		150	150	150	150
$I_q/I_{cu}$ (kA)		150	150	150	150
$I_{cs}$ (kA)		150	150	150	150

$U_{imp} = 6000V$   
 IEC/EN 60947-4-1  
 IEC/EN 60947-2  
 Category A  
 GB/T 14048.2  
 50Hz



Model series  
 Eaton Industries GmbH  
 53105 Bonn, Germany

SEE DIAL FOR MOTOR FULL-LOAD AMPS	MAX. HP	115	200	240	480	600	V
BREAK ALL LINES	3 PH	-	-	-	-	-	HP
TRIP RATING 125% OF DIAL SETTINGS	1 PH	-	-	-	-	-	HP



MAX RMS SYM AMPS | MAX. FUSE | MAX. C. B.  
 50 kA - 600V AC | 600 A | 600 A

SUITABLE FOR GROUP INSTALLATION WHEN PROTECTED BY ANY OF THE FOLLOWING:  
 - LISTED CURRENT LIMITING C.B. PER UL 489  
 - LISTED FUSE

RATED AS SHOWN IN TABLE AND HAVING AN INTERRUPTING RATING NOT LESS THAN INDICATED FOR FIELD WIRING SEE INSTALLATION INSTRUCTIONS



MANUFR. CNTLR. 3408 LISTED

**WARNING**

THE OPENING OF THE BRANCH-CIRCUIT PROTECTIVE DEVICE MAY BE AN INDICATION THAT A FAULT CURRENT HAS BEEN INTERRUPTED. TO REDUCE THE RISK OF FIRE OR ELECTRIC SHOCK, CURRENT-CARRYING PARTS AND OTHER COMPONENTS OF THE CONTROLLER SHOULD BE EXAMINED AND REPLACED IF DAMAGED. IF BURNOUT OF THE CURRENT ELEMENT OF AN OVERLOAD RELAY OCCURS, THE COMPLETE DEVICE MUST BE REPLACED.


**EATON**

PKZM0-0,63  
 XT-PRP63BC1  
 $I_n = 0,63A$

4023 R03



TEST



+ AK - PKZ0

1 L1 3 L2 5 L3

2 T1 4 T2 6 T3