


CERTIFICATION

Applicant : American Power Conversion Holdings Inc., Taiwan Branch
Address : 5F, No. 189, Sec 2, Jiuzong Rd., Neihu Dist., Taipei, Taiwan
Manufacturer : American Power Conversion Holdings Inc., Taiwan Branch
Address : 5F, No. 189, Sec 2, Jiuzong Rd., Neihu Dist., Taipei, Taiwan
Description of EUT : UPS
Trade Name : 
Model Number : BK350EI
Product Series : BK325I, BK325Ilyyyyyyyy, BK350Elyyyyyyyy ("y" can be any alphanumeric, +, *, #, _, - or blank)
Type of Test : **EMC Directive 2014/30/EU for CE Marking**
Technical Standard : **Emission**
EN IEC 62040-2:2018 Environment: First / Classification of EUT: Category C1
IEC 62040-2:2016
EN IEC 61000-3-2:2019+A1:2021
Immunity
EN IEC 62040-2:2018 Environment: First / Classification of EUT: Category C1
IEC 62040-2:2016
IEC 61000-4-2:2008 IEC 61000-4-6:2013
IEC 61000-4-3:2020 IEC 61000-4-8:2009
IEC 61000-4-4:2012 IEC 61000-2-2:2002+A1:2017+A2:2018
IEC 61000-4-5:2017
Report Number : HA220340-CE
Receipt Date : 09-May-2022
Issued Date : 14-Sep-2022
Test Result : **Compliance**

The above equipment was tested by *HongAn TECHNOLOGY CO., LTD.*, for compliance with the requirement set forth in EMC Directive 2014/30/EU and the technical standards mentioned above.

Note :

1. The results of the test report relate only to the sample tested.
2. The test report shall not be reproduced without the written approval of *HongAn TECHNOLOGY CO., LTD.*

Approved by: _____

Adam Yang

Adam Yang



HongAn TECHNOLOGY CO., LTD.

HongAn TECHNOLOGY EMC Laboratory

NO.15-1, CWEISHUH KENG, CWEIPIN VILLAGE,

LINKOU DIST, NEW TAIPEI CITY, TAIWAN, R.O.C.

TEL : +886-2-26030362

FAX : +886-2-26019259

E-mail : hatlab@ms19.hinet.net