

## Single Station Smoke Alarm

10 year sealed battery

**Normal operation:** Red LED flashing once every 50 seconds.

**Alarm status:** Red LED flashes rapidly, and the buzzer sounds a "beep, beep, beep". **Hush:** Red LED flashes 9 seconds and the buzzer does not sound. (Silence time is about 9min) **Fault:** Red LED flashes once every 8 seconds with one "beep"; Replace alarm. **Low battery :** Red LED flashing once every 50 seconds with one "beep"; Replace alarm.


**Not recommended for operation below 0°C or above 40°C or in humidity higher than 93% RH. Test the alarm weekly.**

Factory State:  
press the accessory and  
then fasten the base

 **WARNING — Battery not replaceable — See instruction manual**

**Distributed by:**

Dependo  
Boterbloem 9 ■ Info@dependo.nl  
2671WS Naaldwijk ■ www.dependo.nl



ON  
OFF Factory State Date of manufact

Installation date: \_\_\_\_\_ Repl: **2022-07-14**  
**010112022030300047**



1008  
1008-CPR-69265137  
DOP:



EN14604:2005

Made in china