



CHNT



Test regularly

NB310L

B20 $I_{\Delta n} 0.3A$



6000 $t \leq 0.1s$

3

400V~

IEC/EN61009-1

255864



IPT. EMAT groeopenkasten BV
Wethouder Beverstrat
189/7543BK Enschede /The
Netherlands

