

44x68mm



Smartwares Europe

Jules Verneweg 87,
5015 BH Tilburg
The Netherlands
www.smartwares.eu



85dB(A)



22
1008-CPR-MC 69265752 0001
FSM-126-001CPR

Tested according to:
EN14604:2005
EN14604:2005/AC:2008

Battery type: DC 3V (CR123A)
Replace battery after 1 year

.....M /Y
Date of manufacture
Replace after 10 years



press test button after replacing battery

Wireless protocol:
wifi 2.4GHz



Maximum RF power
transmitted in the
frequency band:
17.57dBm

FSM-126

Batch no.:

.....
EN Fire Safety
Photoelectric smoke
alarm device. Test
monthly. Test operation
after replacing the battery.
Replace only with the
same or equivalent
battery type.