



CHNT

Test regularly

NB310L

B32 $I_{\Delta n} 0.03A$

6000 $I_n \leq 0.1s$

3

400V~

IEC/EN61009-1

660039

I
O

-25



KEMA
KEUR

CE

IPT EMAT groeipenkasten BV
Wethouder Beverstrat
189/7543BK Enschede /The
Netherlands

